

Water Testing Results - Central Point Student Center
Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result	# of Retests	Final Test Result
Bathroom	1707362-001	7/14/2017	2.89 ppb	0	2.89 ppb
Kitchen	1707362-002	7/14/2017	10.3 ppb	0	10.3 ppb
Conference Room	1707362-003	7/14/2017	3.06 ppb	0	3.06 ppb

ND = Non Detect - Lead level is below the set detection limits