

Water Testing Results - East Portland Student Center
Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result	# of Retests	Final Test Result
Bathroom- #1	1707361-001	7/14/2017	ND	0	ND
Bathroom- #2	1707361-002	7/14/2017	ND	0	ND
Kitchen	1707361-003	7/14/2017	3.93 ppb	0	3.93 ppb

ND = Non Detect - Lead level is below the set detection limits